



WCCOM MODEL 48 C/W 75 HP MOTOR
47TR / 61 HP @ 1000RPM 105ST/795CT
TRK per Compressor = 680,000 BTU / Hr

WCCOM MODEL 48 C/W 75 HP MOTOR
47TR / 61 HP @ 1000RPM 105ST/795CT
TRK per Compressor = 680,000 BTU / Hr

WCCOM MODEL 48 C/W 75 HP MOTOR
47TR / 61 HP @ 1000RPM 105ST/795CT
TRK per Compressor = 680,000 BTU / Hr

CONTRACTOR NAME		ACCENT REFRIGERATION SYSTEMS LTD.	
PROJECT NAME		Strohcona Gardens Rec	
ADDRESS		Campbell River, BC	
PROJECT No.	58784-0	PROJECT No.	58784-0
ISSUED BY	ART S	ISSUED BY	ART S
APPROVED BY	ART SUTHERLAND	APPROVED BY	ART SUTHERLAND
DATE	Oct 5th, 2013	DATE	Oct 5th, 2013
SCALE	N/S	SCALE	N/S
SHEET		1 OF 1	
DRAWING NUMBER		M-1	

Refrigeration-Heat Recovery P&ID

SP-1-1004